

LANDSCAPE INFILTRATION: Operation and Maintenance

- During the first year of operation, inspections should be conducted after every major storm and poorly established areas revegetated.
- Sediment accumulation on the surface of the facility should be removed and the top two to three inches of surface layer replaced as needed.
- The top few inches of the planting soil should be removed and replaced when water ponds for more than 48 hours or there is algae growth on the surface of the facility.
- If standing water persists after filter media has been maintained, the gravel, soil and sand may need to be cleaned and/or replaced.
- Occasional pruning and replacement of dead vegetation is necessary. If specific plants are not surviving, more appropriate species should be used. Watering may be required during prolonged dry periods.

